

ADDENDUM NO. 1

CITY OF WINTER GARDEN, FLORIDA

CITY PROJECT NO. 16015

LIFT STATION NO. 41 UPGRADES

AUGUST 9, 2017

This addendum is hereby incorporated into the bid documents of the project referenced above. The following items are clarifications, corrections, additions, deletions and/or revisions to and shall take precedence over the original documents. Additions are indicated by underlining, deletions are indicated by ~~striketrough~~.

A. BIDDER QUESTIONS

1 What is the water main size for the 1-inch Tap?

Based on existing records the water main is 10-inch, the diameter was not verified during the survey. As shown on drawings C03, the City will install a 1-inch water meter and RPZ type backflow preventer. The Contractor will need to connection to the 1-inch connection.

2. Drawing M01 shows an 8-inch 90-degree bend on the plan view, should this fitting be a 10-inch?

Yes, the shown 8-inch 90-degree bend on the plan view should be a 10-inch fitting.

3. How does the force main connect to the existing force main?

The existing discharge force main from LS 41, is approximately 1,970 linear foot, the material is PVC, and the force main was installed in the late 1990s. The force main discharges into a manhole near the intersection of East Division Street and Hennis Road. Based on current records there are no other force mains manifold into the 8-inch force main. The connection to the existing 8-inch force main shall be a direct connection during low flows. Contractor remains responsible for any wastewater spills, cleanup, pumping trucks, and is responsible to keep lift station number 41 from overflowing. A 12-inch by 8-inch reducer will be required on drawing C03.

4. Please provide design option of probable construction cost.

The option of probable construction cost is approximately \$443,000.

B. The following items will be posted to the City's website:

- Sign-in Sheet
- Pre-Bid Agenda

C. The Bidder shall acknowledge receipt of this addendum by completing the applicable section in the solicitation.

D. All other terms and conditions remain the same.